

Criteria for Supported Scaffolds (Construction)

Instructions: This checklist is intended to help you identify potential hazards in your workplace. The questions are based on applicable Federal OSHA standards. Keep in mind that additional state and local regulations may apply, depending upon your location. Please check one answer for each question. If you select “no,” you should investigate further to determine what corrective action may be needed to address the hazard. You can review the specific OSHA Standards outlined below at www.osha.gov/law-regs.html. Choose “General Industry” or “Construction.”

	Questions	OSHA Regulation	Yes	No	N/A
	Criteria for Supported Scaffolds (Construction)				
1)	Are footings level, sound, rigid, and capable of supporting the loaded scaffold without settling or displacement?	1926.451(c)(2)(i)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2)	Are supported scaffold poles, legs, posts, frames, and uprights placed on base plates and mud sills or other firm foundation?	1926.451(c)(2)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3)	Are supported scaffold poles, legs, posts, frames, and uprights plumbed and braced to prevent swaying and displacement?	1926.451(c)(3)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4)	Are supported scaffolds with a height to base width ratio of more than 4 to 1 restrained from tipping by guying, tying, bracing, or equivalents?	1926.451(c)(1)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5)	Is it prohibited to use front-end loaders and similar pieces of equipment to support scaffold platforms, unless they were designed by the manufacturer for such use?	1926.451(c)(2)(iv)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6)	Is it prohibited to use unstable objects as working platforms?	1926.451(c)(2)(iii)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7)	Is it prohibited to use unstable objects for supporting scaffolds and platform units?	1926.451(c)(2)(ii)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Safety Checklist Disclaimer: This safety checklist (the “Material”) is made available to the user or other receiver of the Material for general informational purposes only. The Material has been developed with consideration of various factors relevant to the subject area, including federal laws and regulations in effect at the time the Information was created and/or certain good management practices relevant to the subject area. Because every industry and/or workplace presents unique circumstances, the Material does not constitute and is not intended to provide specific advice, assurances, or guarantees concerning any user’s compliance with particular regulatory requirements (e.g., OSHA) or other applicable safety and/or health requirements or good management practices. The Material does not constitute training and does not replace the need to properly train all employees nor is the Material a substitute for an assessment of any safety or health hazards present at your facility by a health or safety professional or expert. Users are advised to consult with a legal or other professional advisor concerning specific regulatory compliance requirements applicable to their workplaces and appropriate use of the Material. Users and receivers of the Material are subject in all respects to the terms and conditions set forth www.grainger.com, including those provisions relating to limitation of liability. Users and receivers of the Material assume all responsibility and risk arising from any and all use of and/or reliance upon the Material, including any modifications made thereto. W.W. Grainger, Inc. makes no warranty, express or implied, that the Material is current, accurate, appropriate or complete for any particular facility or requirements applicable to a particular facility.