

### Fall Prevention (Construction)

**Instructions:** This checklist is intended to help you identify potential hazards in your workplace. The questions are based on applicable Federal OSHA standards. Keep in mind that additional state and local regulations may apply, depending upon your location. Please check one answer for each question. If you select “no,” you should investigate further to determine what corrective action may be needed to address the hazard. You can review the specific OSHA Standards outlined below at [www.osha.gov/law-regs.html](http://www.osha.gov/law-regs.html). Choose “General Industry” or “Construction.”

	Questions	OSHA Regulation	Yes	No	N/A
	<b>Guardrail Systems</b>				
1)	Are guardrail systems equipped with a gate when they are placed around holes that are used as points of access?	1926.502(b)(13)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2)	Are guardrail systems capable of withstanding, without failure, a force of at least 200 pounds?	1926.502(b)(3)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3)	Are guardrail systems used on ramps and runways erected along each unprotected side or edge?	1926.502(b)(14)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4)	Are midrails installed at a height midway between the top edge of the guardrail system and the walking/working level?	1926.502(b)(2)(i)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5)	Are midrails, screens, or mesh, installed between the top edge of the guardrail system and the walking/working surface when there is no wall or parapet wall at least 21 inches high?	1926.502(b)(2)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6)	Do screens and mesh extend from the top rail to the walking/working level and along the entire opening between top rail supports?	1926.502(b)(2)(ii)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7)	Does your employer use standard railings that consist of a top rail, intermediate rail, toeboard, and posts that have a vertical height of approximately 42 inches from the upper surfaces of the top rail to the floor?	1926.502(b)(1)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8)	If wire rope is used for top rails, is it flagged at 6-foot intervals (or less) with high-visibility material?	1926.502(b)(9)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

## Fall Prevention (Construction)

	Questions	OSHA Regulation	Yes	No	N/A
	<b>Guardrail Systems</b>				
<b>9)</b>	Is it prohibited for the ends of all top rails and midrails to overhang the terminal posts (unless overhang does not cause a hazard)?	1926.502(b)(7)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>10)</b>	When a hole is not in use, is it closed over with a cover, or is a guardrail system provided along all unprotected sides or edges?	1926.502(b)(12)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>11)</b>	When guardrail systems are used at holes, are they erected on all unprotected sides or edges of the hole?	1926.502(b)(11)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	<b>Warning Line Systems</b>				
<b>12)</b>	Are employees prohibited from entering the area between a roof edge and a warning line unless performing roofing work in that area?	1926.502(f)(3)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>13)</b>	Are points of access, materials handling areas, storage areas, and hoisting areas connected to the work area by an access path formed by two warning lines?	1926.502(f)(1)(iii)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>14)</b>	Do control lines consist of ropes, wires, tapes, or equivalent materials, and supporting stanchions?	1926.502(g)(3)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>15)</b>	Do warning lines consist of supporting stanchions and ropes, wires, or chains?	1926.502(f)(2)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>16)</b>	Does the rope, wire, or chain have a minimum tensile strength of 500 pounds?	1926.502(f)(2)(iv)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>17)</b>	Is a warning line erected around all sides of the roof work area?	1926.502(f)(1)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

## Fall Prevention (Construction)

	Questions	OSHA Regulation	Yes	No	N/A
	<b>Warning Line Systems</b>				
<b>18)</b>	Is the rope, wire, or chain flagged at 6-foot intervals (or less) with high-visibility material?	1926.502(f)(2)(i)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>19)</b>	When mechanical equipment is not used, is the warning line erected 6 feet or more from the roof edge?	1926.502(f)(1)(i)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	<b>Controlled-Access Zones</b>				
<b>20)</b>	Are controlled access zones where leading edge and other operations are taking place defined by a control line or by another means that restricts access?	1926.502(g)(1)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>21)</b>	Does each control line have a minimum breaking strength of 200 pounds?	1926.502(g)(3)(iii)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>22)</b>	In areas where overhand bricklaying and related work are taking place, are additional control lines erected at each end to enclose the controlled access zone?	1926.502(g)(2)(iii)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>23)</b>	In areas where overhand bricklaying and related work are taking place, is the controlled access zone defined by a control line erected at least 10 but not more than 15 feet from the working edge?	1926.502(g)(2)(i)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>24)</b>	Is each control line flagged or otherwise clearly marked at 6-foot intervals (or less) with high-visibility material?	1926.502(g)(3)(i)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>25)</b>	Is the control line connected on each side to a guardrail system or wall?	1926.502(g)(1)(iv)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>26)</b>	When control lines are used, are they erected at least 6 but not more than 25 feet from the unprotected or leading edge, except when precast concrete members are erected?	1926.502(g)(1)(i)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

## Fall Prevention (Construction)

	Questions	OSHA Regulation	Yes	No	N/A
	<b>Safety-Monitoring Systems</b>				
<b>27)</b>	Are only employees working on low-sloped roofs, or employees covered by a fall protection plan, allowed in an area where a safety monitoring system is in place?	1926.502(h)(3)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>28)</b>	Do workers in a controlled access zone comply promptly with fall hazard warnings from safety monitors?	1926.502(h)(4)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>29)</b>	Does the safety monitor warn workers when they appear to be unaware of a fall hazard or act in an unsafe manner?	1926.502(h)(1)(ii)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>30)</b>	Has a competent person been designated to monitor the safety of other workers?	1926.502(h)(1)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>31)</b>	Is mechanical equipment kept away from areas where safety monitoring systems are used to monitor employees working on low-slope roofs?	1926.502(h)(2)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>32)</b>	Is the safety monitor close enough to communicate with the workers being monitored?	1926.502(h)(1)(iv)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>33)</b>	Is the safety monitor on the same walking/working surface and within sighting distance of the workers being monitored?	1926.502(h)(1)(iii)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	<b>Covers</b>				
<b>34)</b>	Are all covers secured when installed to prevent displacement by the wind, equipment, or workers?	1926.502(i)(3)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

## Fall Prevention (Construction)

	Questions	OSHA Regulation	Yes	No	N/A
	<b>Covers</b>				
<b>35)</b>	Are all other covers capable of supporting at least twice the weight of workers, equipment, and materials that may be imposed on the cover at any one time?	1926.502(i)(2)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>36)</b>	Are covers color coded, or are they marked with the word "HOLE" or "COVER" to warn of the hazard?	1926.502(i)(4)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>37)</b>	Can covers located in roadways and vehicular aisles support at least twice the maximum axle load of the largest vehicle expected to cross over the cover?	1926.502(i)(1)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

**Safety Checklist Disclaimer:** This safety checklist (the "Material") is made available to the user or other receiver of the Material for general informational purposes only. The Material has been developed with consideration of various factors relevant to the subject area, including federal laws and regulations in effect at the time the Information was created and/or certain good management practices relevant to the subject area. Because every industry and/or workplace presents unique circumstances, the Material does not constitute and is not intended to provide specific advice, assurances, or guarantees concerning any user's compliance with particular regulatory requirements (e.g., OSHA) or other applicable safety and/or health requirements or good management practices. The Material does not constitute training and does not replace the need to properly train all employees nor is the Material a substitute for an assessment of any safety or health hazards present at your facility by a health or safety professional or expert. Users are advised to consult with a legal or other professional advisor concerning specific regulatory compliance requirements applicable to their workplaces and appropriate use of the Material. Users and receivers of the Material are subject in all respects to the terms and conditions set forth [www.grainger.com](http://www.grainger.com), including those provisions relating to limitation of liability. Users and receivers of the Material assume all responsibility and risk arising from any and all use of and/or reliance upon the Material, including any modifications made thereto. W.W. Grainger, Inc. makes no warranty, express or implied, that the Material is current, accurate, appropriate or complete for any particular facility or requirements applicable to a particular facility.